

Joseph M. Foster & Associates

Over 35 years of Diversified  
Architectural Experience

Addendum No. 2

DATE 08.29.19 TO All Bidders

PROJECT NAME Shops @ Sedona Lakes PROJECT NO. 18-38

TRANSMIT VIA:  EMAIL  FAX 1 PAGES

The original specifications & drawings, dated varies for the project referenced above are amended as noted herein.

RFI NO. \_\_\_\_\_ QUESTIONS, SEE BELOW

DESCRIPTION 1. The design windspeed for the building needs to conform to the following:  
a. Inland 11 windspeed = 110 MPH (3 sec gust)  
b. IBC 2012 & 2015 code = Ultimate = 142 MPH  
c. for the following:  
1. FEMB  
2. Storefront  
3. Roof  
4. Canopies  
5. Plaster  
6. Sheathing  
7. Waterproofing  
8. Structure  
9. Any other items required by above

COPIES: \_\_\_\_\_

email [jmfassoc@comcast.net](mailto:jmfassoc@comcast.net)

5503 Valerie Houston, Texas 77081

(713)432-1428 Fax (713)839-1148